

# Plumbing Inspection Checklist

## Construction

### AUDIT VERIFICATION

Please mention the Full Name of Inspector

Please validate the inspection with signature

SIGNATURE

### EXTERNAL CHECKS AND DAMAGES

Is the water pressure at a safe level?

Yes

No

NA

Is there any visible signs of cracks, brittleness, or leaking?

Yes

No

NA

Is the drainage line free from corrosion or any pipe damage?

Yes

No

NA

Did you notice if the gutter was obstructed?

Yes

No

NA

### INTERNAL CHECKS AND DAMAGES

Did you notice any leaks/damages on faucets?

Yes

No

NA

Are there any water drips when the spigot is turned off or when the water is running?

Yes

No

NA

Are there any visible signs of water stains on walls/ceilings?

Yes

No

NA

Are there any loose fitting in the toilet ?

Yes

No

NA

Is there any blockage in water drains?

Yes

No

NA

## OVERVIEW

Are water lines roughed at the correct height and location?

Yes

No

NA

Are med gas outlets installation done at the correct location?

Yes

No

NA

Did you notice pipe insulate in their respective places?

Yes

No

NA

Is the waste outlet capped and fixed at the correct location?

Yes

No

NA

Are all the penetration via floor and are they sealed properly?

Yes

No

NA

Is there any leakage in valves?

Yes

No

NA

Is the plumbing system closely sealed?

Yes

No

NA

Is a test conducted on water piping pressure?

Yes

No

NA

Did you notice any issue with the pipe fittings?

Yes

No

NA

## RECOMMENDATIONS

Are results satisfied?

Yes

No

Please provide your suggestions

textarea

## WATER MARKINGS AND CHECKS

Are used materials properly marked and approved?

Yes

No

NA

Is there an indication of hot to the left and cold to the right?

Yes

No

NA

Are tempering valves installed?

Yes

No

NA

Did bathroom fixtures reach a max. of 50 degree centigrade?

Yes

No

NA

Did you notice proper labels on pipe work?

Yes

No

NA

Is pipe work at every truss or 600mm max on horizontal secured?

Yes

No

NA

Is Pressure test at 1500 Kpa?

Yes

No

NA